## **EENS Job Risk Assessment**

Name(s) of Risk Team Members: E. Hoey, L. Milian, T. Roberts, S. Springston, L. Bowerman, G. Senum, K. Lewis, J. Boccio, P. Carr & A. Piper (facilitators)	Point Value → Parameter ↓	1	2	3	4	5
Job Title: Electrical Work						
Job Number or Job Identifier: EENS-JRA-005	Frequency (B)	<pre><pre><pre><pre></pre></pre></pre></pre>	<pre>≤once/month</pre>	<pre><pre><pre><pre></pre></pre></pre></pre>	<pre><pre><pre><pre><pre></pre></pre></pre><pre><pre></pre></pre><pre></pre></pre><pre></pre></pre> <pre></pre> <pre><td>&gt;once/shift</td></pre>	>once/shift
JRA Date:						
Job Description: Work on BNL Range A, B, and C electrical equipment	Severity (C)	First Aid Only	Medical Treatment	Lost Time	Partial Disability	Death or Permanent Disability
Training Procedures List (Optional): Applicable Standard Operating Procedures:	Likelihood	Very	Unlikely	Possible	Probable	Multiple
Approved by: Date: Rev. #: Draft	(D)	Unlikely	Officery	i ossibie	Tiobable	Manapie
Stressors (if applicable, please list all) Outdoor Work (damp env.),		Reas	on for Revision	(if applicable):		Comments:

				Before Additional Controls					Afte		lditi trols		l			
Activity	Hazard	Control(s)	Stressor	# of People A	Frequency B	Severity C	Likelihood D	Risk* AxBxCxD	Control(s) Added to Reduce Risk	Stressors	# of People A	Frequency B	Severity C	Likelihood D	Risk* AxBxCxD	% Risk Reduction
On a mation of	Electrocution	Cover securely in place, NRTL approved equipment design Training, , appropriate PPE (NFPA 70E	N	1	4	5	1	20								
Operation of disconnects and	Electrical Shock		Ν	1	4	3	1	12								
circuit breakers with the box cover on,	Reflex injury		Ζ	1	4	3	1	12								
(Range A,B,C)	Arc flash burn	compliant), proper equipment grounding,	Z	1	4	4	1	16								
Verify de-energized	Electrocution	Verified de-energized source, Training,	N	1	3	5	2	30								

## **EENS Job Risk Assessment**

			Before Additional Controls					ıl								
Activity	Hazard	Control(s)	Stressor	# of People A	Frequency B	Severity C	Likelihood D	Risk* AxBxCxD	Control(s) Added to Reduce Risk	Stressors	# of People A	Frequency B	Severity C	Likelihood D	Risk* AxBxCxD	% Risk Reduction
state after removing panel/cover	Electrical Shock	qualified/authorized, proper grounding, approved equipment design, standards and	N	1	3	4	3	36								
pane, sere.	Reflex injury	procedures, proper CAT meter, work planning as required, 2 person rule	N	1	3	4	2	24								
	Arc flash burn	appropriate PPE (NFPA 70E compliant),, LOTO	N	1	3	4	1	12								İ
Troubleshooting, testing Low Voltage, Low Current	Electric Shock Training, qualified, proper grounding,	Training, qualified, proper grounding, approved equipment design, standards and	N	1	3	1	3	9								
<50 VDC electronic equipment (Range A)	Reflex injury	procedures, labeling	N	1	3	2	1	6								ı
	Electrocution	, 2 person rule, proper grounding, approved equipment design, appropriate PPE (NFPA	Z	1	2	5	1	10								
Troubleshooting, testing Low Voltage,	Electrical Shock	70E compliant), Training, qualified/authorized, proper grounding,		1	2	1	1	2						L		
High Current electronic equipment (Range B, C)	Reflex injury	approved equipment design, standards and procedures, proper CAT meter, work planning as required, labels signs &	N	1	2	2	1	4								
(Range B, O)	Arc flash burn	postings, clear work area, Inspections , LOTO	N	1	2	3	1	6		$\Box$						1
	Electrocution	Training/qualified, proper grounding, approved equipment design, NFPA 70E		1	2	5	1	10								
Troubleshooting, testing circuits	Electrical Shock	compliant PPE, standards and procedures, proper meter, Permit for Working On or	N	1	2	3	2	12								
(Range B)	Arc flash burn	Near Energized Parts, labels signs & postings, LOTO	N	1	2	2	1	4								
	Reflex injury	(above plus) clear work area, Inspections	N	1	2	3	2	12	_							
	Electrocution	Training, proper grounding, approved equipment design, NFPA 70E compliant	N	2	2	5	1	20								
Troubleshooting,	Electrical Shock	PPE, standards and procedures, proper meter, work planning, labels signs &	N	2	2	4	2	32								
testing circuits (Range C)	Arc flash burn	postings Permit for Working On or Near Energized Parts, LOTO	N	1	2	4	1	8								İ
	Reflex injury	(above plus) clear work area, Tier 1 Inspections	N	1	2	4	2	16								
Trouble shooting and testing high voltage,	Electrocution	Training, qualified/authorized, LOTO, proper grounding, approved equipment design,	N	1	2	5	1	10								
low current power supplies (example:	Electrical Shock	proper cables and connectors, labels and signs, LOTO, work planning, labels signs &	N	1	2	4	1	8								
ion gauges, vacuum gauges)	Reflex injury	postings Permit for Working On or Near Energized Parts, NFPA 70E compliant PPE	N	1	2	2	1	4								

## **EENS Job Risk Assessment**

				Before Additional Controls							After Additional Controls							
Activity	Hazard	Control(s)	Stressor	# of People A	Frequency B	Severity C	Likelihood D	Risk* AxBxCxD	Control(s) Added to Reduce Risk	Stressors	# of People A	Frequency B	Severity C	Likelihood D	Risk* AxBxCxD	% Risk Reduction		
De-energizing	Electrical Shock	Equipment design, training, PPE,	N	1	1	3	1	3										
capacitors in circuitry presumed de-	Arc flash burn	labeling/posting, grounding of capacitors in storage,	N	1	1	4	1	4										
energized	Reflex injury		N	1	1	2	1	2										
	Electrocution Training/qualified, proper grounding, approved equipment design, NFPA 70E	Υ	1	2	5	2	20											
Testing & troubleshooting	Electrical Shock	compliant PPE, standards and procedures, proper meter, Permit for Working On or Near Energized Parts, labels signs &	Υ	1	2	3	2	12										
equipment in damp locations (Ranges A &B)	Arc flash burn		Υ	1	2	2	1	4		Г								
	Reflex injury	(above plus) clear work area, Inspections	Z	1	2	3	2	12										

*Risk:	0 to 20	21 to 40	41-60	61 to 80	81 or greater
	Negligible	Acceptable	Moderate	Substantial	Intolerable